

Carroll County Water System Impovements
Status Update April 2024
by
Underwood Engineers

Status update

- Evaluation of Existing Sources
- Contract #3 - County Building Meters
- Contract #4 – Meter/Chlorination Building and Tank Upgrades
- Hydrants
- Residential Meters
- Fire Pond
- Asset Management Plan (NHDES grant)
- Budget
- Schedule

Water Source Evaluation -Bedrock Aquifer

- BRW-1 and BRW-2 hydraulically connected
- Capacity needs to be considered together
- 25 gpm (36,000 gpd) combined sustainable capacity
- Significantly depressed water table from summer 2023 pumping
- Some recovery was observed following some use of the dug well in the Fall of 2023


Water Source Evaluation -Bedrock Aquifer

- Good Water Quality
 - Elevated radon (4,000-5,000 pCi/L) – unregulated
 - BRW #1 – Iron above SMCL in 1 sample (1.3 mg/l) but ND in other
 - BRW #1 – Manganese at SMCL in 1 sample (0.047 mg/l) below in the other (0.0068 mg/l)
 - pH 7.9 - 8.4

Water Source Evaluation -Bedrock Aquifer

- Recommendations:
 - Recommended max individual well pumping rates:
 - BRW #1 – 20 gpm (throttle from 36 gpm)
 - BRW #2 – 25 gpm (throttle from 30 gpm)
 - Install long-term GW level monitoring
 - Maintain operating water levels above main fracture zones:
 - BRW #1 – 420 ft
 - BRW #2 – 434 ft
 - BRW#1 siphoning in pump house after shut off


Long-Term Monitoring of BRW-1



Plot of Water Level versus Time for September 20 to November 17, 2023

Carroll County Complex
Ossipee, New Hampshire

Long-Term Monitoring of Well BRW-2



Plot of Water Level versus Time for September 20 to November 17, 2023

Carroll County Complex
Ossipee, New Hampshire

Water Source Evaluation – Dug Wells

- Shallow, unconsolidated aquifer is independent from bedrock wells
- Piping infrastructure between W-3, W-2 and W-1 is unknown
- Wells appear to be independent
- Sustainable capacity of W-1 is 12 gpm
 - Pump capacity and DES permitted capacity is also 12 gpm


Water Source Evaluation – Dug Wells

- Good Water Quality
 - Shallow wells more vulnerable to near surface contamination
 - pH 5.4 - 6 (much lower than bedrock wells), lower alkalinity
 - Lower radon (1,000 pCi/L)

Water Source Evaluation – Dug Wells

- Recommendations
 - Additional investigation to confirm if W-2 and W-3 are connected to W-1
 - Additional pump testing & monitoring to better evaluate sustainability during drought conditions
 - Install long – term level monitoring
 - Additional pump testing
 - Install water-tight covers for all 3 wells to prevent potential contamination
 - W-1 siphoning in pump house after shut off
 - Use W-1 regularly in spring/summer to reduce stress on bedrock aquifer


Long-Term Monitoring of Dug Well W-1



Plot of Water Level versus Time for September 20 to November 17, 2023

Carroll County Complex
Ossipee, New Hampshire


Long-Term Monitoring of Dug Well W-2



Plot of Water Level versus Time for September 20 to November 17, 2023

Carroll County Complex
Ossipee, New Hampshire

Long-Term Monitoring of Dug Well W-3



Plot of Water Level versus Time for September 20 to November 17, 2023

Carroll County Complex
Ossipee, New Hampshire

Source Capacity Evaluation

Estimated Existing Demand

Average Day	19,000 gpd
Maximum Day	26,000 gpd

Future

25,250 gpd

- Small Systems Env-Dw 405.1
 - 25-1,000 persons served and without fire protection
 - Required Capacity = 76,000 gpd
 - Available capacity = 53,280 gpd

- Large Systems Env-Dw 404.01(h)
 - Serving >1,000 people or with fire protection
 - ADD with largest source out of service => 19,000 gpd
 - Available capacity = 46,080 gpd
 - MDD with all sources => 26,000 gpd
 - Available capacity = 53,280 gpd

Source Capacity Evaluation

- Existing source capacity appears sufficient for existing uses
- Caveats
 - Existing demands are based on monthly meter reading
 - Unknown impact of drought conditions on dug well system
 - Significant depression of bedrock water table observed after wet summer of 2023
 - Bedrock wells are hydraulically connected
- Make new source development part of any expansion
 - New source location would be away from existing wells

Contract #3 – County Building Meters

- RFP Sent to 6 firms
- 2 Bids received
- Contract being executed with The Backflow Pro, LLC
- Work scheduled for early May

Contract #4 – Meter/chlorination Building & Tank Repairs

- Meters and Piping completed under Contract #2
- Working on final design docs for:
 - Building repairs and upgrades
 - Site upgrades
 - Tank repairs, cleaning
 - SCADA upgrade
 - Dug well cleaning and repairs
- Summer 2024 construction

Contract #5 – Old Route 28 Water Main Replacement

- 30% Design – received DOT comments
- Scheduling meetings with Town DPW
- Borings
- Bid late fall/winter
- Construction 2025

Other projects

- Hydrant replacement
 - Hydrants purchased
 - No UE assistance to date
 - Installation this summer
- Residential meter replacements
 - Meters purchased
 - No UE assistance to date
 - Record meter changeouts in GIS software purchased w/ AMP grant
- Fire Pond
 - No work to date

Asset Management Plan (NHDES grant)

- Field data collected and mapped
- Hardware and software purchased
- Training/workshop today

Budget

- \$2,110,000 Funding
 - \$2,000,000 County ARPA
 - \$50,000 Planning grant (100% disbursed – used for source evaluation)
 - \$60,000 AMP grant (52% disbursed)
- \$2,391,000 Budgeted/Estimated
- \$392,437 spent to date (16%)
- Upcoming projects
 - \$38,454 – Contract #3 County meters
 - \$1,600,000 budgeted
 - Hydrant replacements (this summer)
 - Pump house/storage tank improvements (this summer)
 - Old Route 28 WM replacement (Summer 2025)

Schedule

- Meter building/storage tank final design April 2024
- Complex meters May 2024
- Residential meter replacements 2024-2025
- Meter building/storage tank construction Summer/Fall 2024
- Hydrant replacements Summer 2024
- Old Route 28 Water Main final design September 2024
- Old Route 28 Water Main construction Summer 2025